



CITY OF WEST PARK

FREQUENTLY ASKED QUESTIONS

ITB 24-0116

MARY SAUNDERS PARK - PIONEER WALL

1. Where will the tree be relocated to?
Answer: Please refer to the drawings. However, City will confirm exact location within the park at the time of construction layout.
2. What is the budget for this project?
Answer: Please refer to Project Data Sheet posted with the Bid package.
3. What is the configuration of the wall perforations?
Answer: Please refer to grid provided on Sheet A4.00 as best as possible. This may also be coordinated with City of West Park and the Architectural consultant during construction.
4. How will site be accessed?
Answer: Please include cost of converting existing metal fence pedestrian gate at north side of property immediately, adjacent to the project, to be utilized as the primary construction access point. This will be converted to a hinged double gate (15' min opening width) that will remain in place at the completion of the project for future vehicular park access. Please refer to instructions included in Addendum 1.
5. What is the finish for the concrete wall that will receive the future mural by others?
Answer: Smooth/troweled/level finish.
6. How should work area be protected?
Answer: Contractor shall take all steps necessary to secure the jobsite and any excavated work area(s) by utilizing, at a minimum, orange safety fencing around the work zone and/or any other measures determined necessary for safety by the site superintendent.

-----END Q & A-----